




VEJRSTATION TYPE VD-203

VINDHASTIGHEDSGIVER
4.3519.00.141



VINDRETNINGSGIVER
4.3129.00.141



OBS! ALLE POLARISERINGER SKAL FORBINDES KORREKT

| | | | |
|--------|---|---------|------|
| 4,0mA | = | 0° | NORD |
| 4,5mA | = | 11,25° | |
| 5,0mA | = | 22,5° | |
| 5,5mA | = | 33,75° | |
| 6,0mA | = | 45° | |
| 6,5mA | = | 56,25° | |
| 7,0mA | = | 67,5° | |
| 7,5mA | = | 78,75° | |
| 8,0mA | = | 90° | ØST |
| 8,5mA | = | 101,25° | |
| 9,0mA | = | 112,5° | |
| 9,5mA | = | 123,75° | |
| 10,0mA | = | 135° | |
| 10,5mA | = | 146,25° | |
| 11,0mA | = | 157,5° | |
| 11,5mA | = | 168,75° | |
| 12,0mA | = | 180° | SYD |
| 12,5mA | = | 191,25° | |
| 13,0mA | = | 202,5° | |
| 13,5mA | = | 213,75° | |
| 14,0mA | = | 225° | |
| 14,5mA | = | 236,25° | |
| 15,0mA | = | 247,5° | |
| 15,5mA | = | 258,75° | |
| 16,0mA | = | 270° | VEST |
| 16,5mA | = | 281,25° | |
| 17,0mA | = | 292,5° | |
| 17,5mA | = | 303,75° | |
| 18,0mA | = | 315° | |
| 18,5mA | = | 326,25° | |
| 19,0mA | = | 337,5° | |
| 19,5mA | = | 348,75° | |
| 20,0mA | = | 360° | NORD |

| | | | |
|--|----------|--|-----------|
| mb-teknik ingeniørfirma a-s | | Brøndbytoften 8, 2650 Hvidovre tlf. 36473322 fax 36470222 | |
| Titel: FORBINDELSESDIAGRAM VEJRSTATION | | | |
| Customer: | | Date: 20.02.12 | |
| Mat.: | | Scale: FIT | |
| Order nr.: | Dwg no.: | 310278 | Init.: FB |